



USE PERMIT
FOR CLASS 4, 5, 6 SEWAGE SYSTEMS

APPLICATION NO.
CA-6-87

INSPECTION DETAILS	TIME	DATE	WEATHER
	2:30pm	July 24/87	Rain
REPRESENTING:	THE OWNER	THE INSTALLER	
	owner	Derek Mason	


1. Work authorized by the Certificate of Approval has been satisfactorily completed and includes:
 a) Septic tank holding tank of working capacity of 850 Imp. Gals. constructed of steel concrete fibreglass
 on site or prefabricated to serve 3 (no. of bedrooms or units).

MAKE AND MODEL,
IF PREFABRICATED TANK Orillia Precast.

- b) Leaching bed of total 72 lineal feet of 4 inch diameter distribution pipe of Daymond Clarkson (type and product description e.g. manufacturer(s) and material of which pipe is made) laid in 4 runs and fed by gravity (gravity, siphon, pump).
 c) Proprietary Aerobic System: (Manufacturer) N/A (Model) _____
 d) Other details FILTER BED 12' x 20' = 240 sq. ft.

2. Location

- a) System components installed as shown on application supporting Certificate of Approval
 b) If located other than in (a) use space below for sketch and dimensions from permanent points of reference sufficient to facilitate future location of tank and leaching bed including orientation of pipe runs.



3. The following work remains to be completed:-

- Backfill System and Complete Finish Grading to Shed Run-off and Divert Water Around Leaching Bed
 Stabilize All Sloped Surfaces Other Topsoil + seed

USE PERMIT

Under Section 67 of the Environmental Protection Act, and subject to the provisions of the Act and Regulations a Permit is hereby issued to (Owner) _____ for the use and operation of the Class 4F sewage system constructed installed/enlarged/extended/altered pursuant to the Certificate of Approval issued under the above application number in accordance with the application and Certificate of Approval with any changes indicated above and located on Lot _____ Concession _____ Ward/Township/Municipality Cadwell Region/District/County Muskoka Lakes Plan No. BR 1513 Sub-Lot No. 7

INSPECTED AND RECOMMENDED BY <u>Sandy Ross</u>	PERMIT ISSUED BY <u>[Signature]</u> DIRECTOR	DATE ISSUED <u>July 28/87</u>
---	--	----------------------------------

Note: Section 64(a) of the Act provides that no change can be made to any building(s) or structure(s) in connection with which this sewage system is used, if the operation or effectiveness of the sewage system will or is likely to be affected by the change, unless a new Certificate of Approval is obtained.
 Section 121 of the Act provides that an applicant for a permit may appeal a decision to refuse to issue a permit. Written notice of appeal must be forwarded to the Director (who refused to issue the permit) and to the Environmental Appeal Board, 1 St. Clair Avenue West, Toronto, Ontario, M4V 1K7 within 15 days of receipt of a permit.